

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No. F.6/DFS/MS/School/WZ/2019/576

Dated: 31/07/2019

**FIRE SAFETY CERTIFICATE**

Certified that the **Sant Gyaneshwar Model School, Lakhmi Enclave, Extended Lal Dora, Alipur, Delhi- 110036**, comprised of Ground +2 floor owned / occupied by **Sant Gyaneshwar Model School**, has already been issued Fire Safety Certificate Vide letter No. F-6/DFS/MS/2016/1163 dated 03/06/2016. The premises was re-inspected by the officer concerned of Fire Service on 16.07.2019 in the presence of Mrs. Promila Singh (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed compiled with Circular No. F.16/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 & NBC (Part-IV) and that the building / premises is fit for occupancy class Educational (Group-B) with effect from 31/07/2019 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

**Issued on 31/07/2019 at New Delhi by.**

  
**(DHARAMPLA BHARDWA)**  
**DY. CHIEF FIRE OFFICER.**

Copy to :-

1. The Principal, Sant Gyaneshwar Model School, Lakhmi Enclave, Extended Lal Dora, Alipur, Delhi-110036.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. **"The owner / Occupier shall apply for renewal of this Fire Safety certificate to the Director in Form 'I' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry"**
7. **There shall not be more than 45 students in class rooms in any case.**